

CONSTRUCTION STANDARDS
FOR NON-DISTRICT USE OF DISTRICT RIGHTS-OF-WAY

The following Standards are meant to supplement the Protection Standards in Chapter 16 “Regulations for Non-District Use of Salt Lake Aqueduct and Point of the Mountain Aqueduct Rights of Way”, adopted September 15, 2008.

A. If unusual conditions are proposed for the Encroachment Improvements or unusual field conditions within the Corridor are encountered, as designated and characterized by the District, the District may, at its discretion, impose conditions or requirements which are different from or more stringent than those prescribed in these Guidelines.

B. All backfill material within the Corridor shall be compacted to ninety percent (90%) of maximum density, unless otherwise allowed or required by the District. Mechanical compaction shall not be allowed within six inches (6") of any of the District's facilities and pipeline(s). Mechanical compaction using heavy equipment, as designated and characterized by the District, will not be allowed over District facilities and pipeline(s) or within eighteen inches (18") horizontally.

C. Backfilling of any excavation or around any facilities or pipeline(s) within the Corridor shall be compacted in layers not exceeding six inches (6") thick to the following requirements: (1) cohesive soils to 90 percent (90%) maximum density specified by ASTM Part 19, D-698, method A; (2) noncohesive soils to 70 percent (70%) relative density specified by ANSI/ASTM Part 19, d-2049, par. 7.1.2, wet method.